

Clark County Public Works

Bid Inquiry Log

Last Update: 4-Jun-12

Link to the CRP Inquiry Submittal Form: <http://www.clark.wa.gov/general-services/purchasing/ccpwcprp.html>

Return to the Current Bid Information Page: <http://www.clark.wa.gov/general-services/purchasing/crp.html>

Project CRP: 314022

Title: 2012 County-Wide HMA Overlays

Engineer in Charge: Glen Bedell

Date: 5/30/12

Question (1): Does the Clark County want a specific bid bond form? I do not see a sample form in the bid documents. Please let me know what form of bid bond is acceptable.

Reference: Unanswered

Answer: The bond form is in the proposal packet. If you access "Specs" on the Builders Exchange page you will see that it begins on their page 19.

Date: 5/31/12

Question (2): 1-05.4 Construction Surveying for Padden Parkway calls for verification of control. Where is the control sheet in the plans, and where is the monument table to facilitate preservation of existing survey monumentation?

Reference: UNANSWERED

Answer: See pending Addendum # 1.

Date: 5/31/12

Question (3): 1-05.4 Construction Surveying for Padden Parkway calls for staking of the centerline of all alignments. Where is the alignment sheet and supporting information in the plan set?

Reference: UNANSWERED

Answer: See pending Addendum # 1.

Date: 5/31/12

Question (4): 1-05.4 Construction Surveying for Padden Parkway calls for additional topography in order to match into existing roadways. Where is the existing topography shown in the plans?

Reference: UNANSWERED

Answer: See pending Addendum # 1.

Date: 5/31/12

Question (5): In regards to the existing quadrapole loops is there a minimum or maximum lenght for the 4 saw cuts to seal

Reference: Sheets 24 thru 26

Answer: It is expected the cuts will be made with a circular blade of sufficient diameter to completely sever the loops, that process determining the dimensions of the cavities to be filled with loop sealant.

Date: 5/31/12

Question (6): Bid Item #14 is asking for a paving fabric reinforcement, what are the specifications or properties of the fabric that you are requiring. The broad statement of "paving fabric reinforcement" is not specific enough to know what type or grade of geotextile you are looking for.

Reference: UNANSWERED

Answer: See pending Addendum # 1.

Date: 6/4/12

Question (7): Addendum 1 states that the contractor shall notify the engineer of any monuments not shown by the plans and reference prior to construction. There are no monuments shown on the plans and the surveyor is required to file a permit to destroy with DNR unless this has already been done by the County. Is this permit in place?

Reference: UNANSWERED

Answer: Yes, the permit is in place.

Date: 6/4/12

Question (8): Regarding Public Liability and Property Damage Insurance - would \$2m occurrence based with proof of \$5m in excess along with \$3m OCP satisfy the insurance requirements for this project?

Reference: UNANSWERED

Answer: The insurance requirements for this contract are specified in Section 1-07.18 "Public Liability and Property Damage Insurance" of Standard Specifications for Road, Bridge and Municipal Construction, 2012, Washington State Department of Transportation.

Date: 6/4/12

Question (9): The striping drawings indicate there are Plastic lines (i.e. Plastic White Wide Line) to be installed, but no corresponding bid items.

Reference: UNANSWERED

Answer: Refer to Standard Specification 1-04.1(2) "Bid Items Not Included in the Proposal".
